

CERTIFICATE OF CONFORMITY

Product Listing Scheme: Scheme Type 5

This certificate is issued to: Allegion (Southeast Asia) Pte Ltd

31 Ubi Road 1

#07-01

Singapore 408694

Registration Number/UEN: 200007123E

Product: Controlled Door Closing Device

(Concealed Door Closer)

Brand: BRITON

Model: C3620

Country of Origin: Taiwan

Product Details: Adjustable power size cam action concealed door closer

without back check function using sliding arm

Suitable for use on 120mins uninsulated fire rated doors

Classification of Coding System:

		•			
3	8	6 3	1	1	0

See COC Appendix (1 page) for more details

SS 332:2018 Clause 6 (Annex C) Standard(s):

Report(s): Exova No. WIL 375896

This certificate issued in accordance with SCDF Fire Code 2018 requirements.







Certificate No.

Date of Original Issue

No. of Page(s)

Date of Last Revision

Date of Expiry

21A0418

07 May 2021

1 of 2

06 May 2026

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of Singapore Test Services Pte Ltd ("STS") and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the Product Listing Scheme of STS. The above certified company is solely responsible for compliance of any product that has the same designation as the product type tested. Parties relying on this Certificate should verify its validity with STS.



APPENDIX

Product Details: Adjustable power size cam action concealed door closer

without back check function using sliding arm

Classification of coding system for concealed door closer as per below

<u>1st Digit</u> Category of Use	2nd Digit Test Duration	<u>3rd Digit</u> Door Closer Power Size	<u>4th Digit</u> Fire Resistance	<u>5th Digit</u> Essential requirements of safety use	6th Digit Corrosion Resistance
3	8	6 3	1	1	0
Grade 3	Grade 8	Power Sizes: 3 to 6	Grade 1	Grade 1	Grade 0
For closing door	500,000 cycles	(Can be used on fire	*Suitable for	Satisfied essential	no defined
from 105°	•	rated doors)	120mins	requirements of safety	corrosion
		,	uninsulated fire	use	resistance
			rated doors.		

^{*}Please refer to TÜV SÜD PSB No. 7191252325-MEC21-SW.

Head of Certification

Certificate No.

Date of Original Issue

No. of Page(s)

Date of Last Revision

Date of Expiry

21A0418

07 May 2021

2 of 2

-

06 May 2026

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of Singapore Test Services Pte Ltd ("STS") and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the Product Listing Scheme of STS. The above certified company is solely responsible for compliance of any product that has the same designation as the product type tested. Parties relying on this Certificate should verify its validity with STS.