

CERTIFICATE OF CONFORMITY

Product Listing Scheme: Scheme Type 5

This certificate is issued to: Allegion (Southeast Asia) Pte Ltd
31 Ubi Road 1
#07-01
Singapore 408694

Registration Number/UEN: 200007123E

Product: Controlled Door Closing Device
(Surface Mounted Door Closer)

Brand: CISA

Model: C1415, C1422

Country of Origin: China

Product Details: Fixed power sized rack and pinion surface mounted door closer
without back check function with regular arm
Suitable for use on 30mins insulated fire rated doors
Classification of Coding System:

4	8	3	1	1	0
---	---	---	---	---	---

See COC Appendix (1 page) for more details

Standard(s): SS 332:2018 Clause 6 (Annex C)

Report(s): Exova No. WIL - 380055

This certificate issued in accordance with SCDF Fire Code 2018 requirements.



Head of Certification



Certificate No. 21A0397	Date of Original Issue 14 April 2021	No. of Page(s) 1 of 2	Date of Last Revision -	Date of Expiry 13 April 2026
-----------------------------------	--	---------------------------------	-----------------------------------	--



APPENDIX

Product Details: Fixed power sized rack and pinion surface mounted door closer without back check function with regular arm
Classification of coding system for surface mounted door closer as per below

<u>1st Digit</u> Category of Use	<u>2nd Digit</u> Test Duration	<u>3rd Digit</u> Door Closer Power Size	<u>4th Digit</u> Fire Resistance	<u>5th Digit</u> Essential requirements of safety use	<u>6th Digit</u> Corrosion Resistance
4	8	3	1	1	0
Grade 4 For closing door from 180°	Grade 8 500,000 cycles	Power Sizes: 3 Can be used on fire rated doors	Grade 1 *Suitable for 30mins insulated fire rated doors.	Grade 1 Satisfied essential requirements of safety use	Grade 0 no defined corrosion resistance

Please refer to WF Report No. 388801.

Note: For surface-mounted door closers, the selected door closer shall meet the performance requirements needed for the respective fire-rated door, in accordance with SS 332 Cl 6 Annex C or EN 1154. Surface-mounted door closers tested with uninsulated fire-rated doors can be installed on insulated or uninsulated fire-rated doors (subject to the maximum fire-rating attained by the door closer in a fire test). Surface-mounted door closers tested with insulated fire-rated doors can only be installed on insulated fire-rated doors

Head of Certification

Certificate No. 21A0397	Date of Original Issue 14 April 2021	No. of Page(s) 2 of 2	Date of Last Revision -	Date of Expiry 13 April 2026
-----------------------------------	--	---------------------------------	-----------------------------------	--